



**Functional  
Devices, Inc.**

# Bulletin B519

• RIBM2402SB 393012C

Functional Devices, Inc.  
101 Commerce Drive  
Sharpville, IN 46068  
Phone: (800) 888-5538  
functionaldevices.com

### COIL RATINGS


INPUT ISOLATED  
FROM OUTPUT  
47 mA @ 30 Vdc  
83 mA @ 24 Vac  
69 mA @ 208-277 Vac

### CONTACT RATINGS

20A Resistive @ 277 Vac  
1 HP @ 120 Vac  
2 HP @ 277 Vac  
20 A Ballast @ 277 Vac (N/O)  
10 A Ballast @ 277 Vac (N/C)  
10 A Tungsten @ 120 Vac (N/O)  
770 VA Pilot @ 120 Vac  
1110 VA Pilot @ 277 Vac

**Connect Yellow Jumper  
Wire to N/O or N/C**

N/O N/C  
○ ○



SIGNALING



LISTED  
13CY  
15M6

### TYPE F, G, EM

For use with  
Smoke Control System  
General Signaling  
Equip. NM

### CONTACTS

Relay Contacts

Not Used

### COIL

- Comm
- 24Vac/dc
- 208-277Vac

- 
- 
-